

40 C.F.R. § 57.302

Performance level of interim constant controls.

- (a) Maximum feasible efficiency. Each NSO shall require: that the smelter operate its interim constant control systems at their maximum feasible efficiency, including the making of any improvements necessary to correct the effects of any serious deficiencies; that the process and control equipment be maintained in the way best designed to ensure such operation; and that process operations be scheduled and coordinated to facilitate treatment of process gas streams to the maximum possible extent. Maximum feasible efficiency shall be expressed in the NSO in the form of a limitation on the concentration of SO₂ in the tail gas of each individual control system in combination with an appropriate averaging period, as provided below in paragraphs (b) and (c) of this section.
- (b) The limitation level for SO₂concentration in the control system tail gas. The level at which the concentration limitation is set shall take into account fluctuations in the strength and volume of process off-gases to the extent that those fluctuations affect the SO₂ content of the tail gas and cannot be avoided by improved scheduling and coordination of process operations. The limitation shall exclude the effect of any increase in emissions caused by process or control equipment malfunction. The limitation shall take into account unavoidable catalyst deterioration in sulfuric acid plants, but may prescribe the frequency of catalyst screening or replacement. The NSO shall also prohibit the smelter owner from using dilution air to meet the limitation.

This document is only available to subscribers. Please log in or purchase access.

Purchase Login