
40 C.F.R. § 60.1240

How do I make sure my continuous emission monitoring systems are operating correctly?

- (a) Conduct initial, daily, quarterly, and annual evaluations of your continuous emission monitoring systems that measure oxygen (or carbon dioxide), sulfur dioxide, nitrogen oxides (Class I municipal waste combustion units only), and carbon monoxide.
- (b) Complete your initial evaluation of the continuous emission monitoring systems within 60 days after your municipal waste combustion unit reaches the maximum load level at which it will operate, but no later than 180 days after its initial startup.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)