

---

## 40 C.F.R. § 60.4345

---

### What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?

---

If the option to use a NO<sub>x</sub> CEMS is chosen:

- (a) Each NO<sub>x</sub> diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO<sub>x</sub> diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)