

40 C.F.R. § 60.563

Monitoring requirements.

- (a) Whenever a particular item of monitoring equipment is specified in this section to be installed, the owner or operator shall install, calibrate, maintain, and operate according to manufacturer's specifications that item as follows:
- (1) A temperature monitoring device to measure and record continuously the operating temperature to within 1 percent (relative to degrees Celsius) or ± 0.5 °C (± 0.9 °F), whichever is greater.
 - (2) A flame monitoring device, such as a thermocouple, an ultraviolet sensor, an infrared beam sensor, or similar device to indicate and record continuously whether a flare or pilot light flame is present, as specified.
 - (3) A flow monitoring indicator to indicate and record whether or not flow exists at least once every fifteen minutes.
 - (4) An organic monitoring device (based on a detection principle such as infrared, photoionization, or thermal conductivity) to indicate and record continuously the concentration level of organic compounds.
 - (5) A specific gravity monitoring device to measure and record continuously to within 0.02 specific gravity unit.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)