
40 C.F.R. § 1065.362

Non-stoichiometric raw exhaust FID O₂ interference verification.

- (a) *Scope and frequency.* If you use FID analyzers for raw exhaust measurements from engines that operate in a non-stoichiometric mode of combustion (e.g., compression-ignition, lean-burn), verify the amount of FID O₂ interference upon initial installation and after major maintenance.
- (b) *Measurement principles.* Changes in O₂ concentration in raw exhaust can affect FID response by changing FID flame temperature. Optimize FID fuel, burner air, and sample flow to meet this verification. Verify FID performance with the compensation algorithms for FID O₂ interference that you have active during an emission test.
- (c) *System requirements.* Any FID analyzer used during testing must meet the FID O₂ interference verification according to the procedure in this section.
- (d) *Procedure.* Determine FID O₂ interference as follows, noting that you may use one or more gas dividers to create the reference gas concentrations that are required to perform this verification:
- (1) Select three span reference gases that contain a C₃H₈ concentration that you use to span your analyzers before emission testing. Use only span gases that meet the specifications of § 1065.750. You may use CH₄ span reference gases for FIDs calibrated on CH₄ with a nonmethane cutter. Select the three balance gas concentrations such that the concentrations of O₂ and N₂ represent the minimum, maximum, and average O₂ concentrations expected during testing. The requirement for using the average O₂ concentration can be removed if you choose to calibrate the FID with span gas balanced with the average expected oxygen concentration.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)