
40 C.F.R. § 141.100

Criteria and procedures for public water systems using point-of-entry devices.

- (a) Public water systems may use point-of-entry devices to comply with maximum contaminant levels only if they meet the requirements of this section.
- (b) It is the responsibility of the public water system to operate and maintain the point-of-entry treatment system.
- (c) The public water system must develop and obtain State approval for a monitoring plan before point-of-entry devices are installed for compliance. Under the plan approved by the State, point-of-entry devices must provide health protection equivalent to central water treatment. “Equivalent” means that the water would meet all national primary drinking water regulations and would be of acceptable quality similar to water distributed by a well-operated central treatment plant. In addition to the VOCs, monitoring must include physical measurements and observations such as total flow treated and mechanical condition of the treatment equipment.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)