

---

## 40 C.F.R. § 141.175

---

### Reporting and recordkeeping requirements.

---

In addition to the reporting and recordkeeping requirements in § 141.75, a public water system subject to the requirements of this subpart that provides conventional filtration treatment or direct filtration must report monthly to the State the information specified in paragraphs (a) and (b) of this section beginning January 1, 2002. In addition to the reporting and recordkeeping requirements in § 141.75, a public water system subject to the requirements of this subpart that provides filtration approved under § 141.173(b) must report monthly to the State the information specified in paragraph (a) of this section beginning January 1, 2002. The reporting in paragraph (a) of this section is in lieu of the reporting specified in § 141.75(b)(1).

(a) Turbidity measurements as required by § 141.173 must be reported within 10 days after the end of each month the system serves water to the public. Information that must be reported includes:

- (1) The total number of filtered water turbidity measurements taken during the month.
- (2) The number and percentage of filtered water turbidity measurements taken during the month which are less than or equal to the turbidity limits specified in § 141.173(a) or (b).

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)