

40 C.F.R. § 141.405

Reporting and recordkeeping for ground water systems.

(a) *Reporting.* In addition to the requirements of § 141.31, a ground water system regulated under this subpart must provide the following information to the State:

(1) A ground water system conducting compliance monitoring under § 141.403(b) must notify the State any time the system fails to meet any State-specified requirements including, but not limited to, minimum residual disinfectant concentration, membrane operating criteria or membrane integrity, and alternative treatment operating criteria, if operation in accordance with the criteria or requirements is not restored within four hours. The ground water system must notify the State as soon as possible, but in no case later than the end of the next business day.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)