

## 40 C.F.R. § 415.242

---

### Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

---

- (a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart and reacting anhydrous ammonia with hydrogen chloride gas must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): There shall be no discharge of process wastewater pollutants to navigable waters.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)