

## 40 C.F.R. § 415.302

---

**Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).**

---

- (a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart and using the milk of lime process must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)