

40 C.F.R. § 419.22

Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

(a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available:

Pollutant or pollutant property	BPT effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
	Metric units (kilograms per 1,000 m ³ of feedstock)	
BOD ₅	28.2	15.6
TSS	19.5	12.6
COD ₁	210.0	109
Oil and grease	8.4	4.5
Phenolic compounds	0.21	0.10
Ammonia as N	18.8	8.5
Sulfide	0.18	0.082
Total chromium	0.43	0.25
Hexavalent chromium	0.035	0.016
pH	(2)	(2)
	English units (pounds per 1,000 bbl feedstock)	
BOD ₅	9.9	5.5
TSS	6.9	4.4
COD ₁	74.0	38.4
Oil and grease	3.0	1.6

Phenolic compounds	0.074	0.036
Ammonia as N	6.6	3.0
Sulfide	0.065	0.029
Total chromium	0.15	0.088
Hexavalent chromium	0.012	0.0056
pH	(2)	(2)

¹ See footnote following table in § 419.13(d).

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)