

# 40 C.F.R. § 419.36

## Standards of performance for new sources (NSPS).

(a) Any new source subject to this subpart must achieve the following new source performance standards (NSPS):

Pollutant or pollutant property	NSPS Effluent Limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed
	Metric units (kilograms per 1,000 m <sup>3</sup> of feedstock)	
BOD <sub>5</sub>	21.8	11.6
TSS	14.9	9.5
COD <sub>1</sub>	133.0	69.0
Oil and grease	6.6	3.5
Phenolic compounds	0.158	.077
Ammonia as N	23.4	10.7
Sulfide	0.140	0.063
Total chromium	0.32	0.19
Hexavalent chromium	0.025	0.012
pH	( 2 )	( 2 )
	English units (pounds per 1,000 bbl of feedstock)	
BOD <sub>5</sub>	7.7	4.1
TSS	5.2	3.3
COD <sub>1</sub>	47.0	24.0
Oil and grease	2.4	1.3
Phenolic compounds	0.056	0.027
Ammonia as N	8.3	3.8

Sulfide	0.050	0.022
Total chromium	0.116	0.068
Hexavalent chromium	0.0096	0.0044
pH	( 2)	( 2)

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)