

# 40 C.F.R. § 421.156

## Pretreatment standards for new sources.

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources. The mass of wastewater pollutants in primary beryllium process wastewater introduced into a POTW shall not exceed the following values:

(a) Solvent extraction raffinate from bertrandite ore.

### PSNS for the Primary Beryllium Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of beryllium carbonate produced from bertrandite ore as beryllium	
Beryllium	1,842.000	831.000
Chromium (total)	831.000	336.900
Copper	2,875.000	1,370.000
Cyanide (total)	449.200	179.700
Ammonia (as N)	299,400.000	131.600.000
Fluoride	78,610.000	44,700.000

(b) Solvent extraction raffinate from beryl ore.

### PSNS for the Primary Beryllium Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of beryllium carbonate produced from beryl ore as beryllium	
Beryllium	180.4	81.4
Chromium (total)	81.4	33.0
Copper	281.6	134.2
Cyanide (total)	44.0	17.6
Ammonia (as N)	29.330.0	12,890.0

Fluoride	7,700.0	4,378.0
----------	---------	---------

(c) Beryllium carbonate filtrate.

PSNS for the Primary Beryllium Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of beryllium carbonate produced as beryllium	
Beryllium	175.900	79.370
Chromium (total)	79.370	32.180
Copper	274.600	130.800
Cyanide (total)	42.900	17.160
Ammonia (as N)	28,590.000	12,570.000
Fluoride	7,508.000	4,269,000

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)