
40 C.F.R. § 421.216

Pretreatment standards for new sources.

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources. The mass of wastewater pollutants in primary molybdenum and rhenium process wastewater introduced into a POTW shall not exceed the following values:

(a) Molybdenum sulfide leachate.

PSNS for the Primary Molybdenum and Rhenium Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of molybdenum sulfide leached	
Arsenic	0.644	0.287
Lead	0.130	0.060
Nickel	0.255	0.171
Selenium	0.380	0.171
Molybdenum	[Reserved]	[Reserved].
Ammonia (as N)	61.720	27.130
Fluoride	16.210	9.214

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)