
40 C.F.R. § 421.232

Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable technology currently available:

(a) Raw Material dust control.

BPT Limitations for the Primary Nickel and Cobalt Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of copper, nickel, and cobalt in the crushed raw material	
Copper	0.146	0.077
Nickel	0.148	0.098
Ammonia (as N)	10.260	4.512
Cobalt	0.016	0.007
Total suspended solids	3.157	1.502
pH	(1)	(1)

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)