

40 C.F.R. § 421.262

Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable technology currently available:

(a) Furnace wet air pollution control.

BPT Limitations for the Secondary Precious Metals Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/troy ounce of precious metals, including silver, incinerated or smelted	
Copper	136.400	71.800
Cyanide (total)	20.820	8.616
Zinc	104.800	43.800
Ammonia (as N)	9,571.000	4,207.000
Combined metals	21.54	
Total suspended solids	2,944.000	1,400.000
pH	(1)	(1)

¹ Within the range of 7.5 to 10.0 at all times.

(b) Raw material granulation.

BPT Limitations for the Secondary Precious Metals Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/troy ounce of precious metal in the granulated raw material	
Copper	12.050	6.340
Cyanide (total)	1.839	0.761

Zinc	9.256	3.867
Ammonia (as N)	845.100	371.500
Combined metals	1.902	
Total suspended solids	259.900	123.600
pH	(1)	(1)

¹ Within the range of 7.5 to 10.0 at all times.

(c) Spent plating solutions.

BPT Limitations for the Secondary Precious Metals Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/liter of spent plating solution used as a raw material	
Copper	1.900	1.000
Cyanide (total)	0.290	0.120
Zinc	1.460	0.610
Ammonia (as N)	133.300	58.600
Combined metals	0.300	
Total suspended solids	41.000	19.500
pH	(1)	(1)

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)