

40 C.F.R. § 421.315

Pretreatment standards for existing sources.

Except as provided in 40 CFR 403.7, any existing source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for existing sources. The mass of wastewater pollutants in secondary tungsten and cobalt process wastewater introduced into a POTW shall not exceed the following values:

(a) Tungsten detergent wash and rinse.

PSES for the Secondary Tungsten and Cobalt Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of tungsten scrap washed	
Copper	0.250	0.119
Nickel	0.107	0.072
Ammonia (as N)	25.990	11.430
Cobalt	0.538	0.236
Tungsten	0.679	0.302

(b) Tungsten leaching acid.

PSES for the Secondary Tungsten and Cobalt Subcategory

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of tungsten produced	
Copper	3.291	1.569
Nickel	1.414	0.951
Ammonia (as N)	342.700	150.700
Cobalt	7.096	3.111
Tungsten	8.947	3.985

This document is only available to subscribers. Please log in or purchase access.

Purchase Login