

40 C.F.R. § 424.25

Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/Mwh)	
TSS	0.032	0.016
Chromium total	.001	.0005
Chromium VI	.0001	.00005
Manganese total	.011	.005
Cyanide total	.0005	.0003
Phenols	.0004	.0002
pH	(1)	(1)
	English units (lb/Mwh)	
TSS	.071	.035
Chromium total	.002	.0012
Chromium VI	.0002	.0001
Manganese total	.023	.012
Cyanide total	.001	.0006
Phenols	.0009	.0005
pH	(1)	(1)

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)

