
40 C.F.R. § 430.12

Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

(a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT), except that non-continuous dischargers shall not be subject to the maximum day and average of 30 consecutive days limitations but shall be subject to annual average effluent limitations:

Subpart A

[BPT effluent limitations]

Pollutant or pollutant property	Kg/kkg (or pounds per 1,000 lb) of product		
	Continuous dischargers		Non-continuous dischargers
	Maximum for any 1 day	Average of daily values for 30 consecutive days	
BOD ₅	23.6	12.25	6.88
TSS	37.3	20.05	11.02
pH	(1)	(1)	(1)

¹ Within the range of 5.0 to 9.0 at all times.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)