

---

# 40 C.F.R. § 432.42

---

## Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).

---

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BPT:

(a) Facilities that slaughter no more than 50 million pounds per year (in units of LWK) must achieve the following limitations:

(1) In the case of process wastewater associated with the slaughtering of animals on-site or the processing of the carcasses of animals slaughtered on-site:

### Effluent Limitations

[BPT]

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
BOD <sub>5</sub> <sup>2</sup>	0.48	0.24
Fecal Coliform	(3)	(4)
O&G <sup>5</sup>	0.26	0.13
TSS <sup>2</sup>	0.62	0.31

<sup>1</sup> Pounds per 1000 lbs (or g/kg) LWK.

<sup>2</sup> The values for BOD<sub>5</sub> and TSS are for average plants, i.e., plants where the ratio of avg. wt. of processed meat products/avg. LWK is 0.55. Adjustments can be made for high-processing packinghouses operating at other such ratios according to the following equations: lbs BOD<sub>5</sub>/1000 lbs LWK = 0.21 + 0.23 (v - 0.4) and lbs TSS/1000 lbs LWK = 0.28 + 0.3 (v - 0.4), where v equals the following ratio: lbs processed meat products/lbs LWK.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)