

# 40 C.F.R. § 437.14

## New source performance standards (NSPS).

(a) Except as provided in § 437.10(b), any new source subject to this subpart must achieve the following performance standards:

### Performance Standards

Regulated parameter	Maximum daily <sup>1</sup>	Maximum monthly avg. <sup>1</sup>
<b>Conventional Parameters</b>		
O&G	205	50.2
pH	( 2)	( 2)
TSS	29.6	11.3
<b>Metal Parameters</b>		
Antimony	0.111	0.0312
Arsenic	0.0993	0.0199
Cadmium	0.782	0.163
Chromium	0.167	0.0522
Cobalt	0.182	0.0703
Copper	0.659	0.216
Lead	1.32	0.283
Mercury	0.000641	0.000246
Nickel	0.794	0.309
Selenium	0.176	0.0698
Silver	0.0318	0.0122
Tin	0.0955	0.0367
Titanium	0.0159	0.00612

Vanadium	0.0628	0.0518
Zinc	0.657	0.252

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)