
40 C.F.R. § 439.22

Effluent limitations attainable by the application of the best practicable control technology currently available (BPT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the application of BPT:

(a) The limitation for BOD₅ is the same as specified in § 439.12(a). No facility shall be required to attain a monthly average limitation for BOD₅ that is less than the equivalent of 45 mg/L.

(1) The long-term average daily BOD₅ load of the raw process wastewater (*i.e.*, the base number to which the percent reduction is applied) is defined as the average daily BOD₅ load during any calendar month, over 12 consecutive months within the most recent 36 months, and must include one or more periods during which production was at a maximum.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)