

## 40 C.F.R. § 439.4

---

### General limitation or standard for pH.

---

The pH must remain within the range 6.0 to 9.0 in any discharge subject to BPT, BCT or NSPS limitations or standards in this part.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)