
40 C.F.R. § 761.30

Authorizations.

The following non-totally enclosed PCB activities are authorized pursuant to section 6(e)(2)(B) of TSCA:

(a) *Use in and servicing of transformers (other than railroad transformers).* PCBs at any concentration may be used in transformers (other than in railroad locomotives and self-propelled railroad cars) and may be used for purposes of servicing including rebuilding these transformers for the remainder of their useful lives, subject to the following conditions:

(1) *Use conditions.* (i) As of October 1, 1985, the use and storage for reuse of PCB Transformers that pose an exposure risk to food or feed is prohibited.

(ii) As of October 1, 1990, the use of network PCB Transformers with higher secondary voltages (secondary voltages equal to or greater than 480 volts, including 480/277 volt systems) in or near commercial buildings is prohibited. Network PCB Transformers with higher secondary voltages which are removed from service in accordance with this requirement must either be reclassified to PCB Contaminated or non PCB status, placed into storage for disposal, or disposed.

(iii) Except as otherwise provided, as of October 1, 1985, the installation of PCB Transformers, which have been placed into storage for reuse or which have been removed from another location, in or near commercial buildings is prohibited.

(A) Retrofilled mineral oil PCB Transformers may be installed for reclassification purposes indefinitely after October 1, 1990.

(B) Once a retrofilled transformer has been installed for reclassification purposes, it must be tested 3 months after installation to ascertain the concentration of PCBs. If the PCB concentration is below 50 ppm, the transformer can be reclassified as a non-PCB Transformer. If the PCB concentration is between 50 and 500 ppm, the transformer can be reclassified as a PCB-Contaminated transformer. If the PCB concentration remains at 500 ppm or greater, the entire process must either be repeated until the transformer has been reclassified to a non-PCB or PCB-Contaminated transformer in accordance with paragraph (a)(2)(v) of this section or the transformer must be removed from service.

(iv) As of October 1, 1990, all higher secondary voltage radial PCB Transformers, in use in or near commercial buildings, and lower secondary voltage network PCB Transformers not located in sidewalk vaults in or near commercial buildings (network transformers with secondary voltages below 480 volts) that have not been removed from service as provided in paragraph (a)(1)(iv)(B) of this section, must be equipped with electrical protection to avoid transformer ruptures caused by high current faults. As of February 25, 1991, all lower secondary voltage radial PCB Transformers, in use in or near commercial buildings, must be equipped with electrical protection to avoid transformer ruptures caused by high current faults.

(A) Current-limiting fuses or other equivalent technology must be used to detect sustained high current faults

and provide for the complete deenergization of the transformer (within several hundredths of a second in the case of higher secondary voltage radial PCB Transformers and within tenths of a second in the case of lower secondary voltage network PCB Transformers), before transformer rupture occurs. Lower secondary voltage radial PCB Transformers must be equipped with electrical protection as provided in paragraph (a)(1)(iv)(E) of this section. The installation, setting, and maintenance of current-limiting fuses or other equivalent technology to avoid PCB Transformer ruptures from sustained high current faults must be completed in accordance with good engineering practices.

(B) All lower secondary voltage network PCB Transformers not located in sidewalk vaults (network transformers with secondary voltages below 480 volts), in use in or near commercial buildings, which have not been protected as specified in paragraph (a)(1)(iv)(A) of this section by October 1, 1990, must be removed from service by October 1, 1993.

(C) As of October 1, 1990, owners of lower secondary voltage network PCB Transformers, in use in or near commercial buildings which have not been protected as specified in paragraph (a)(1)(iv)(A) of this section and which are not located in sidewalk vaults, must register in writing those transformers with the EPA Regional Administrator in the appropriate region. The information required to be provided in writing to the Regional Administrator includes:

(1) The specific location of the PCB Transformer(s).

(2) The address(es) of the building(s) and the physical location of the PCB Transformer(s) on the building site(s).

(3) The identification number(s) of the PCB Transformer(s).

(D) As of October 1, 1993, all lower secondary voltage network PCB Transformers located in sidewalk vaults (network transformers with secondary voltages below 480 volts) in use near commercial buildings must be removed from service.

(E) As of February 25, 1991, all lower secondary voltage radial PCB Transformers must be equipped with electrical protection, such as current-limiting fuses or other equivalent technology, to detect sustained high current faults and provide for the complete deenergization of the transformer or complete deenergization of the faulted phase of the transformer within several hundredths of a second. The installation, setting, and maintenance of current-limiting fuses or other equivalent technology to avoid PCB Transformer ruptures from sustained high current faults must be completed in accordance with good engineering practices.

(v) As of October 1, 1990, all radial PCB Transformers with higher secondary voltages (480 volts and above, including 480/277 volt systems) in use in or near commercial buildings must, in addition to the requirements of paragraph (a)(1)(iv)(A) of this section, be equipped with protection to avoid transformer ruptures caused by sustained low current faults.

(A) Pressure and temperature sensors (or other equivalent technology which has been demonstrated to be effective in early detection of sustained low current faults) must be used in these transformers to detect sustained low current faults.

(B) Disconnect equipment must be provided to insure complete deenergization of the transformer in the event of a sensed abnormal condition (e.g., an overpressure or overtemperature condition in the transformer), caused by a sustained low current fault. The disconnect equipment must be configured to operate automatically within 30 seconds to 1 minute of the receipt of a signal indicating an abnormal condition from a sustained low current fault, or can be configured to allow for manual deenergization from a manned on-site control center upon the receipt of an audio or visual signal indicating an abnormal condition caused by a sustained low current fault. Manual

deenergization from a manned on-site control center must occur within 1 minute of the receipt of the audio or visual signal indicating an abnormal condition caused by a sustained low current fault. If automatic operation is selected and a circuit breaker is utilized for disconnection, it must also have the capability to be manually opened if necessary.

(C) The enhanced electrical protective system required for the detection of sustained low current faults and the complete and rapid deenergization of transformers must be properly installed, maintained, and set sensitive enough (in accordance with good engineering practices) to detect sustained low current faults and allow for rapid and total deenergization prior to PCB Transformer rupture (either violent or non violent rupture) and release of PCBs.

(vi)

(A) No later than December 28, 1998 all owners of PCB Transformers, including those in storage for reuse, must register their transformers with the Environmental Protection Agency, National Program Chemicals Division, Office of Pollution Prevention and Toxics (7404), 1200 Pennsylvania Ave., NW., Washington, DC 20460. This registration requirement is subject to the limitations in paragraph (a)(1) of this section.

(1) A transformer owner who assumes a transformer is a PCB-Contaminated transformer, and discovers after December 28, 1998 that it is a PCB-Transformer, must register the newly-identified PCB Transformer, in writing, with the Environmental Protection Agency no later than 30 days after it is identified as such. This requirement does not apply to transformer owners who have previously registered with the EPA PCB Transformers located at the same address as the transformer that they assumed to be PCB-Contaminated and later determined to be a PCB Transformer.

(2) A person who takes possession of a PCB Transformer after December 28, 1998 is not required to register or re-register the transformer with the EPA.

(B) Any person submitting a registration under this section must include:

(1) Company name and address.

(2) Contact name and telephone number.

(3) Address where these transformers are located. For mobile sources such as ships, provide the name of the ship.

(4) Number of PCB Transformers and the total weight in kilograms of PCBs contained in the transformers.

(5) Whether any transformers at this location contain flammable dielectric fluid (optional).

(6) Signature of the owner, operator, or other authorized representative certifying the accuracy of the information submitted.

(C) A transformer owner must retain a record of each PCB Transformer's registration (e.g., a copy of the registration and the return receipt signed by EPA) with the inspection and maintenance records required for each PCB Transformer under paragraph (a)(1)(xii)(I) of this section.

(D) A transformer owner must comply with all requirements of paragraph (a)(1)(vi)(A) of this section to continue the PCB-Transformer's authorization for use, or storage for reuse, pursuant to this section and TSCA section 6(e)(2)(B).

(vii) As of December 1, 1985, PCB Transformers in use in or near commercial buildings must be registered with

building owners. For PCB Transformers located in commercial buildings, PCB Transformer owners must register the transformers with the building owner of record. For PCB Transformers located near commercial buildings, PCB Transformer owners must register the transformers with all owners of buildings located within 30 meters of the PCB Transformer(s). Information required to be provided to building owners by PCB Transformer owners includes but is not limited to:

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)