

40 C.F.R. § 280.40

General requirements for all UST systems.

(a) Owners and operators of UST systems must provide a method, or combination of methods, of release detection that:

- (1) Can detect a release from any portion of the tank and the connected underground piping that routinely contains product;
- (2) Is installed and calibrated in accordance with the manufacturer's instructions;
- (3) Beginning on October 13, 2018, is operated and maintained, and electronic and mechanical components are tested for proper operation, in accordance with one of the following: manufacturer's instructions; a code of practice developed by a nationally recognized association or independent testing laboratory; or requirements determined by the implementing agency to be no less protective of human health and the environment than the two options listed in paragraphs (a)(1) and (2) of this section. A test of the proper operation must be performed at least annually and, at a minimum, as applicable to the facility, cover the following components and criteria:

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)