

## 40 C.F.R. § 280.42

---

### Requirements for hazardous substance UST systems.

---

Owners and operators of hazardous substance UST systems must provide containment that meets the following requirements and monitor these systems using § 280.43(g) at least every 30 days:

(a) Secondary containment systems must be designed, constructed, and installed to:

- (1) Contain regulated substances leaked from the primary containment until they are detected and removed;
- (2) Prevent the release of regulated substances to the environment at any time during the operational life of the UST system; and

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)