

40 C.F.R. § 466.03

Monitoring and reporting requirements.

(a) Periodic analyses for chromium as may be required under part 122 or 403 of this chapter is not required when both of the following conditions are met.

(1) The first wastewater sample of each calendar year has been analyzed and found to contain less than 0.08 mg/l chromium.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)