

---

# 40 C.F.R. § 467.22

---

## Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

---

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

### Subpart B

#### Core

Pollutant or pollutant property	BPT effluent limitations	
	Maximum for any 1 day	Maximum for monthly average
	mg/off-kg (lb/million off-lbs) of aluminum rolled with emulsions	
Chromium	0.057	0.024
Cyanide	0.038	0.016
Zinc	0.19	0.079
Aluminum	0.84	0.416
Oil and grease	2.60	1.56
Suspended solids	5.33	2.53
pH	(1)	(1)

<sup>1</sup> Within the range of 7.0 to 10.0 at all times.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)