

40 C.F.R. § 471.44

Pretreatment standards for existing sources (PSES).

Except as provided in 40 CFR 403.7 and 403.13, any existing source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and by August 23, 1985 achieve the following pretreatment standards for existing sources (PSES). The mass of wastewater pollutants in precious metals forming process wastewater introduced into a POTW shall not exceed the following values:

- (a) *Rolling spent neat oils—subpart D—PSES.* There shall be no discharge of process wastewater pollutants.
- (b) *Rolling spent emulsions.*

Subpart D—PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/off-kg (pounds per million off-pounds) of precious metals rolled with emulsions	
Cadmium	0.026	0.012
Copper	0.147	0.077
Cyanide	0.023	0.010
Silver	0.032	0.013

- (c) *Drawing spent neat oils—subpart D—PSES.* There shall be no discharge of process wastewater pollutants.
- (d) *Drawing spent emulsions.*

Subpart D—PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/off-kg (pounds per million off-pounds) of precious metals drawn with emulsions	
Cadmium	0.016	0.007
Copper	0.091	0.048
Cyanide	0.014	0.006
Silver	0.020	0.008

This document is only available to subscribers. Please log in or purchase access.

Purchase Login