

40 C.F.R. § 503.24

Management practices.

- (a) Sewage sludge shall not be placed on an active sewage sludge unit if it is likely to adversely affect a threatened or endangered species listed under section 4 of the Endangered Species Act or its designated critical habitat.
- (b) An active sewage sludge unit shall not restrict the flow of a base flood.
- (c) When a surface disposal site is located in a seismic impact zone, an active sewage sludge unit shall be designed to withstand the maximum recorded horizontal ground level acceleration.
- (d) An active sewage sludge unit shall be located 60 meters or more from a fault that has displacement in Holocene time, unless otherwise specified by the permitting authority.
- (e) An active sewage sludge unit shall not be located in an unstable area.
- (f) An active sewage sludge unit shall not be located in a wetland, except as provided in a permit issued pursuant to section 402 or 404 of the CWA.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)