

40 C.F.R. § 257.72

Liner design criteria for new CCR surface impoundments and any lateral expansion of a CCR surface impoundment.

- (a) New CCR surface impoundments and lateral expansions of existing and new CCR surface impoundments must be designed, constructed, operated, and maintained with either a composite liner or an alternative composite liner that meets the requirements of § 257.70(b) or (c).
- (b) Any liner specified in this section must be installed to cover all surrounding earth likely to be in contact with CCR. Dikes shall not be constructed on top of the composite liner.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)