

40 C.F.R. § 261.196

Response to leaks or spills and disposition of leaking or unfit-for-use tank systems.

A tank system or secondary containment system from which there has been a leak or spill, or which is unfit for use, must be removed from service immediately, and the remanufacturer or other person that stores or treats the hazardous secondary material must satisfy the following requirements:

- (a) *Cessation of use; prevent flow or addition of materials.* The remanufacturer or other person that stores or treats the hazardous secondary material must immediately stop the flow of hazardous secondary material into the tank system or secondary containment system and inspect the system to determine the cause of the release.
- (b) *Removal of material from tank system or secondary containment system.* (1) If the release was from the tank system, the remanufacturer or other person that stores or treats the hazardous secondary material must, within 24 hours after detection of the leak or, if the remanufacturer or other person that stores or treats the hazardous secondary material demonstrates that it is not possible, at the earliest practicable time, remove as much of the material as is necessary to prevent further release of hazardous secondary material to the environment and to allow inspection and repair of the tank system to be performed.
- (2) If the material released was to a secondary containment system, all released materials must be removed within 24 hours or in as timely a manner as is possible to prevent harm to human health and the environment.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)