

---

## 40 C.F.R. § 261.410

---

### Preparedness and prevention.

---

- (a) *Maintenance and operation of facility.* Facilities generating or accumulating hazardous secondary material must be maintained and operated to minimize the possibility of a fire, explosion, or any unplanned sudden or non-sudden release of hazardous secondary materials or hazardous secondary material constituents to air, soil, or surface water which could threaten human health or the environment.
- (b) *Required equipment.* All facilities generating or accumulating hazardous secondary material must be equipped with the following, *unless* none of the hazards posed by hazardous secondary material handled at the facility could require a particular kind of equipment specified below:
- (1) An internal communications or alarm system capable of providing immediate emergency instruction (voice or signal) to facility personnel;
  - (2) A device, such as a telephone (immediately available at the scene of operations) or a hand-held two-way radio, capable of summoning emergency assistance from local police departments, fire departments, or state or local emergency response teams;

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)