

40 C.F.R. § 264.174

Inspections.

At least weekly, the owner or operator must inspect areas where containers are stored. The owner or operator must look for leaking containers and for deterioration of containers and the containment system cause by corrosion or other factors. See §§ 264.15(c) and 264.171 for remedial action required if deterioration or leaks are detected.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)