
40 C.F.R. § 265.191

Assessment of existing tank system's integrity.

- (a) For each existing tank system that does not have secondary containment meeting the requirements of § 265.193, the owner or operator must determine that the tank system is not leaking or is unfit for use. Except as provided in paragraph (c) of this section, the owner or operator must obtain and keep on file at the facility a written assessment reviewed and certified by a qualified Professional Engineer in accordance with § 270.11(d) of this chapter, that attests to the tank system's integrity by January 12, 1988.
- (b) This assessment must determine that the tank system is adequately designed and has sufficient structural strength and compatibility with the waste(s) to be stored or treated to ensure that it will not collapse, rupture, or fail. At a minimum, this assessment must consider the following:

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)