

40 C.F.R. § 265.195

Inspections.

- (a) The owner or operator must inspect, where present, at least once each operating day, data gathered from monitoring and leak detection equipment (e.g., pressure or temperature gauges, monitoring wells) to ensure that the tank system is being operated according to its design.

Note:

Section 265.15(c) requires the owner or operator to remedy any deterioration or malfunction he finds. Section 265.196 requires the owner or operator to notify the Regional Administrator within 24 hours of confirming a release. Also, 40 CFR part 302 may require the owner or operator to notify the National Response Center of a release.

- (b) Except as noted under the paragraph (c) of this section, the owner or operator must inspect at least once each operating day:

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)