

40 C.F.R. § 267.193

What testing must I do?

You must test all new tanks and ancillary equipment for tightness before you place them in use. If you find a tank system that is not tight, you must perform all repairs necessary to remedy the leak(s) in the system before you cover, enclose, or place the tank system into use.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)