

---

## 40 C.F.R. § 65.156

---

### General monitoring requirements for control and recovery devices.

---

(a) *General monitoring requirement applicability.* (1) This section applies to the owner or operator of a regulated source required to monitor under this subpart.

(2) Flares subject to § 65.147(c) are not subject to the requirements of this section.

(3) Flow indicators are not subject to the requirements of this section.

(b) *Conduct of monitoring.* (1) Monitoring shall be conducted as set forth in this section and in the relevant sections of this subpart unless either of the following provisions applies:

(i) The Administrator specifies or approves the use of minor or intermediate changes in the specified monitoring requirements or procedures as provided in § 65.7(b), (c), and (d); or

(ii) The Administrator specifies or approves the use of major changes in the specified monitoring requirements or procedures as provided in § 65.7(b), (c), and (d).

(2) When one CPMS is used as a backup to another CPMS, the owner or operator shall report the results from the CPMS used to meet the monitoring requirements of this subpart. If both such CPMS are used during a particular reporting period to meet the monitoring requirements of this part, then the owner or operator shall report the results from each CPMS for the relevant compliance period.

(c) *Operation and maintenance of continuous parameter monitoring systems.* (1) All monitoring equipment shall be installed, calibrated, maintained, and operated according to manufacturers specifications or other written procedures that provide adequate assurance that the equipment would reasonably be expected to monitor accurately.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)