

## 40 C.F.R. § 65.161

## Continuous records and monitoring system data handling.

- (a) *Continuous records.* Where this subpart requires a monitoring device capable of providing a continuous record, the owner or operator shall maintain the record specified in paragraph (a)(1), (2), (3), or (4) of this section, as applicable (The provisions of this section apply to owners and operators of storage vessels and low-throughput transfer racks only if specified by the applicable monitoring plan established under § 65.165(c)(1) and (2)):
- (1) A record of values measured at least once every 15 minutes or each measured value for systems that measure more frequently than once every 15 minutes; or
- (2) A record of block average values for 15-minute or shorter periods calculated from all measured data values during each period or from at least one measured data value per minute if measured more frequently than once per minute; or
- (3) For data collected from an automated continuous parameter monitoring system, a record of block hourly average values calculated from each 15-minute block average period or from at least one measured value per minute if measured more frequently than once per minute, and a record of the most recent 3 valid hours of continuous (15-minute or shorter) records meeting the requirements of paragraph (a)(1) or (2) of this section. Records meeting the requirements of paragraph (a)(1) or (2) of this section shall also be kept for all periods that include CPMS breakdown or malfunction. During these periods, it is not necessary to calculate hourly averages; or
- (4) A record as required by an alternative approved under § 65.162(d).
- (b) Excluded data. Monitoring data recorded during the following periods shall not be included in any average computed to determine compliance under this subpart:
- (1) Monitoring system breakdowns, repairs, preventive maintenance, calibration checks, and zero (low-level) and high-level adjustments;
- (2) Periods of non-operation of the process unit (or portion thereof), resulting in cessation of the emissions to which the monitoring applies; and
- (3) Startups, shutdowns, and malfunctions.
- (c) Records of daily averages. In addition to the records specified in paragraph (a) of this section, owners or operators shall also keep records as specified in paragraphs (c)(1) and (2) of this section unless an alternative monitoring or recordkeeping system has been requested and approved under § 65.162(d).
- (1) Except as specified in paragraph (c)(2) of this section, daily average values of each continuously monitored parameter shall be calculated for each operating day. Data meeting the specifications of paragraph (b) of this

section shall not be included in the average. The data shall be reported in the periodic report as specified in $\S 65.166(f)$ , if applicable.
This document is only available to subscribers. Please log in or purchase access.
<u>Purchase</u> <u>Login</u>
copyright © 2024 by Society of Corporate Compliance and Ethics (SCCE) & Health Care Compliance Association (HCCA). No claim to original US covernment works. All rights reserved. Usage is governed under this website's <u>Terms of Use</u> .