

## 40 C.F.R. § 75.30

---

### General provisions.

---

- (a) Except as provided in § 75.34, the owner or operator shall provide substitute data for each affected unit using a continuous emission monitoring system according to the missing data procedures in this subpart whenever the unit combusts any fuel and:
- (1) A valid, quality-assured hour of SO<sub>2</sub> concentration data (in ppm) has not been measured and recorded for an affected unit by a certified SO<sub>2</sub> pollutant concentration monitor, or by an approved alternative monitoring method under subpart E of this part, except as provided in paragraph (d) of this section; or
  - (2) A valid, quality-assured hour of flow data (in scfh) has not been measured and recorded for an affected unit from a certified flow monitor, or by an approved alternative monitoring system under subpart E of this part; or
  - (3) A valid, quality-assured hour of NO<sub>x</sub> emission rate data (in lb/mmBtu) has not been measured or recorded for an affected unit, either by a certified NO<sub>x</sub>-diluent continuous emission monitoring system or by an approved alternative monitoring system under subpart E of this part; or
  - (4) A valid, quality-assured hour of CO<sub>2</sub> concentration data (in percent CO<sub>2</sub>, or percent O<sub>2</sub> converted to percent CO<sub>2</sub> using the procedures in appendix F to this part) has not been measured and recorded for an affected unit, either by a certified CO<sub>2</sub> continuous emission monitoring system or by an approved alternative monitoring method under subpart E of this part; or
  - (5) A valid, quality-assured hour of NO<sub>x</sub> concentration data (in ppm) has not been measured or recorded for an affected unit, either by a certified NO<sub>x</sub> concentration monitoring system used to determine NO<sub>x</sub> mass emissions, as defined in § 75.71(a)(2), or by an approved alternative monitoring system under subpart E of this part; or

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)