

40 C.F.R. § 75.42

Reliability criteria.

To demonstrate reliability equal to or better than the continuous emission monitoring system, the owner or operator shall demonstrate that the alternative monitoring system is capable of providing valid 1-hr averages for 95.0 percent or more of unit operating hours over a 1-yr period and that the system meets the applicable requirements of appendix B of this part.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)