

## 40 C.F.R. § 76.15

---

### Test methods and procedures.

---

(a) The owner or operator may use the following tests as a basis for the report required by § 76.10(e)(7):

- (1) Conduct an ultimate analysis of coal using ASTM D 3176-89 (incorporated by reference as specified in § 76.4);
- (2) Conduct a proximate analysis of coal using ASTM D 3172-89 (incorporated by reference as specified in § 76.4); and
- (3) Measure the coal mass flow rate to each individual burner using ASME Power Test Code 4.2 (1991), “Test Code for Coal Pulverizers” or ISO 9931 (1991), “Coal—Sampling of Pulverized Coal Conveyed by Gases in Direct Fired Coal Systems” (incorporated by reference as specified in § 76.4).

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)