
40 C.F.R. § 96.204

Applicability.

(a) Except as provided in paragraph (b) of this section:

(1) The following units in a State shall be CAIR SO₂ units, and any source that includes one or more such units shall be a CAIR SO₂ source, subject to the requirements of this subpart and subparts BBB through HHH of this part: any stationary, fossil-fuel-fired boiler or stationary, fossil-fuel-fired combustion turbine serving at any time, since the later of November 15, 1990 or the start-up of the unit's combustion chamber, a generator with nameplate capacity of more than 25 MWe producing electricity for sale.

(2) If a stationary boiler or stationary combustion turbine that, under paragraph (a)(1) of this section, is not a CAIR SO₂ unit begins to combust fossil fuel or to serve a generator with nameplate capacity of more than 25 MWe producing electricity for sale, the unit shall become a CAIR SO₂ unit as provided in paragraph (a)(1) of this section on the first date on which it both combusts fossil fuel and serves such generator.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)