
40 C.F.R. § 97.530

General monitoring, recordkeeping, and reporting requirements.

The owners and operators, and to the extent applicable, the designated representative, of a CSAPR NO_x Ozone Season Group 1 unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this subpart and subpart H of part 75 of this chapter. For purposes of applying such requirements, the definitions in § 97.502 and in § 72.2 of this chapter shall apply, the terms “affected unit,” “designated representative,” and “continuous emission monitoring system” (or “CEMS”) in part 75 of this chapter shall be deemed to refer to the terms “CSAPR NO_x Ozone Season Group 1 unit,” “designated representative,” and “continuous emission monitoring system” (or “CEMS”) respectively as defined in § 97.502, and the term “newly affected unit” shall be deemed to mean “newly affected CSAPR NO_x Ozone Season Group 1 unit”. The owner or operator of a unit that is not a CSAPR NO_x Ozone Season Group 1 unit but that is monitored under § 75.72(b)(2) (ii) of this chapter shall comply with the same monitoring, recordkeeping, and reporting requirements as a CSAPR NO_x Ozone Season Group 1 unit.

(a) *Requirements for installation, certification, and data accounting.* The owner or operator of each CSAPR NO_x Ozone Season Group 1 unit shall:

(1) Install all monitoring systems required under this subpart for monitoring NO_x mass emissions and individual unit heat input (including all systems required to monitor NO_x emission rate, NO_x concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with §§ 75.71 and 75.72 of this chapter);

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)