

40 C.F.R. § 97.76

Additional requirements to provide heat input data.

The owner or operator of a NO_x Budget unit that monitors and reports NO_x mass emissions using a NO_x concentration system and a flow system shall also monitor and report heat input rate at the unit level using the procedures set forth in part 75 of this chapter.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)