

40 C.F.R. § 98.301

Reporting threshold.

- (a) You must report GHG emissions from an electric power system if the total nameplate capacity of SF₆ and PFC containing equipment (excluding hermetically sealed-pressure equipment) located within the facility, when added to the total nameplate capacity of SF₆ and PFC containing equipment (excluding hermetically sealed-pressure equipment) that is not located within the facility but is under common ownership or control, exceeds 17,820 pounds and the facility meets the requirements of § 98.2(a)(1).

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)