

40 C.F.R. § 62.15175

What continuous emission monitoring systems must I install for gaseous pollutants?

- (a) You must install, calibrate, maintain, and operate continuous emission monitoring systems for oxygen (or carbon dioxide), sulfur dioxide, and carbon monoxide. If you operate a Class I municipal waste combustion unit, also install, calibrate, maintain, and operate a continuous emission monitoring system for nitrogen oxides. Install the continuous emission monitoring system for sulfur dioxide, nitrogen oxides, and oxygen (or carbon dioxide) at the outlet of the air pollution control device.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)