

40 C.F.R. § 63.1085

What are the general requirements for heat exchange systems?

Unless you meet one of the requirements for exemptions in § 63.1084, you must meet the requirements in paragraphs (a) through (f) of this section.

- (a) Except as specified in paragraph (e) of this section, you must monitor the cooling water for the presence of substances that indicate a leak according to § 63.1086(a) through (d).
- (b) Except as specified in paragraph (f) of this section, if you detect a leak, then you must repair it according to § 63.1087(a) and (b) unless repair is delayed according to § 63.1088(a) through (c).

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)