

## 40 C.F.R. § 63.1090

---

### What reports must I submit?

---

If you delay repair for your heat exchange system, you must report the delay of repair in the semiannual report required by § 63.1110(e). If the leak remains unrepaired, you must continue to report the delay of repair in semiannual reports until you repair the leak. Except as provided in paragraph (f) of this section, you must include the information in paragraphs (a) through (e) of this section in the semiannual report.

- (a) The fact that a leak was detected, and the date that the leak was detected.
- (b) Whether or not the leak has been repaired.
- (c) The reasons for delay of repair. If you delayed the repair as provided in § 63.1088(b), documentation of emissions estimates.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)