
40 C.F.R. § 63.11120

What testing and monitoring requirements must I meet?

- (a) Each owner or operator, at the time of installation, as specified in § 63.11113(e), of a vapor balance system required under § 63.11118(b)(1), and every 3 years thereafter, must comply with the requirements in paragraphs (a)(1) and (2) of this section.
- (1) You must demonstrate compliance with the leak rate and cracking pressure requirements, specified in item 1(g) of Table 1 to this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section.
- (i) California Air Resources Board Vapor Recovery Test Procedure TP-201.1E, —Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves, adopted October 8, 2003 (incorporated by reference, see § 63.14).
- (ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in § 63.7(f).

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)